

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Procedo Flooring

1404 E. 6th Street, Tuscumbia, AL, United States

For the following product(s):

Rubber Flooring and Accessories:

Maxime Rubber Tile, Maxime Plus Rubber Flooring, Procedo Rubber Stair Treads and Risers, Procedo Rubber Wall Base, Procedo Thermoplastic Rubber Wall Base, Procedo Vinyl Wall Base, Procedo Sculptured Wall Base and Procedo Vinyl Accessories



The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)



ISO/IEC 17065
Product Certification Body
#0821

Registration # SCS-FS-02615

Valid from: July 1, 2020 to June 30, 2021

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President

SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA